

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Zhejiang Ruihua Machinery Co., Ltd	Client ID	102557
Company Other Name		Type of Certification	Product Certification; System 1
Certification Standard	AS 2419.4-2021 : Fire hydrant installations Storz fittings for firefighting purposes		
Scheme	Global-Mark Product Conformance - Certified product type program		
Certification Review Date	10/05/2024	Certification Expiry Date	10/05/2027
Certificate Issue Date	10/05/2024	Certificate Last Update Date	


APPROVED COMPANY / SITE ADDRESS(ES):

Western Industrial Zone, Lingshan Town Yuyao Zhejiang 315460 China

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager




Unique Certificate Code: C907A8F8B312EBC9CA258AF90020222D

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®

JAS-ANZ



WWW.JAS-ANZ.ORG/REGISTER

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
ISP-STORZ-MFBF	Storz adaptor	Ruihua	Storz Adaptor – Female thread, 2 1/2" (65mm), Working pressure: 40 Bar, Material: Forged AlMgSi Alloy	25-Mar-24

Comments:

End of the document



Certification Manager

